



Full stall washdown urinal with top spud

# K-25039-T

## **Features**

- Full stall washdown urinal.
- 0.5 or 1.0 gpf (1.9 or 3.8 lpf).
- Lip of urinal installs below floor level for easier cleaning around fixture.
- Full length sidewalls provide added privacy.
- External trapway.
- 3/4" (19 mm) top spud.

## Material

Vitreous china.

## Installation

Replaces K-4920-T.

## **Recommended Products/Accessories**

K-10675 Touchless washdown 0.5 gpf flushometer

K-10958 Touchless DC 0.5 gpf washdown urinal flushometer

K-10960 Touchless DC washdown 1.0 gpf urinal flushometer

K-13518 Manual 1.0 GPF Wshdwn Flushometer

K-13519 Manual 0.5 GPF Urinal Flushometer

K-4932 Urinal Seam Cover

K-9172 Urinal Strainer

K-9183 Urinal Strainer

K-23726 Drain treatment

K-23725 Cast iron cleaner

## **Included Components**

Additional Components:

18376 Urinal Spud Accessory 3/4"







## Codes/Standards

ASME A112.19.2/CSA B45.1 DOE - Energy Policy Act 1992 EPA WaterSense® California Energy Commission (CEC) ADA ICC/ANSI A117.1 CSA B651 OBC

# **KOHLER® One-Year Limited** Warranty

See website for detailed warranty information.

## **Available Colors/Finishes**

Color tiles intended for reference only.


Color	Code	Description
	0	White
	96	Biscuit
	47	Almond
	7	Black Black™








# Full stall washdown urinal with top spud K-25039-T





## **Technical Information**

All product dimensions are nominal.

Flush outlet Washout

technology:

Spud size: 3/4, Inlet, Top Min. Water per 0.5 gal (1.9 L)

Flush:

Max. Water per 1 gal (3.8 L)

Flush:

Designed for the above water use when installed with a water-saving flushometer.

# **Pressure and Supply Requirements**

Fixture pressure min 20 psi (137.9 kPa)

(static):

Fixture pressure 80 psi (551.6 kPa)

max (static):

## **Notes**

Install this product according to the installation instructions.

Refer to manufacturer's instructions and local codes for flushometer requirements.

ADA, OBC, CSA B651 compliant when installed to the specific requirements of these regulations.

